

5/29/2020

State of Tennessee  
Sourcing Event 34101-11515

Questions/Answers

1. Will the existing Fuel dispenser – submersible pump – loading arm – meter – and pumping unit for loading arm be re-used or do we need to quote new ones?

Answer Quote all new

2. What is the product being stored Gasoline – Diesel – Jet Fuel as shown in photo? ( if it is jet fuel the tank will need to have an internal coating)

Answer: F24-Diesel is stored

3. Will the steps remain to be re-used?

Answer: with the new tank having a ladder on it there is no need for the steps

4. Who is responsible for the pumping out and disposal of fuel in existing tank?

Answer: Customer will pump out fuel and store until new tank is installed, vender is responsible for pumping, disposal, and documentation of sludge.